



| TAG# | LOCATION | DIA[IN] | KEFLEX PART # | DESIGN PRESSURE | OAL | AXIAL FORCE TO COMPRESS [LBS] |
|------|----------|---------|---------------|-----------------|-----|-------------------------------|
| | | 2" | - | | | |
| | | 2 1/2" | - | | | |
| | | 3" | - | | | |
| | | 4" | - | | | |
| | | 5" | - | | | |
| | | 6" | - | | | |
| | | 8" | F080H311DB906 | 300PSI | 36" | 750 |
| | | 10" | F100H311DB906 | 300PSI | 36" | 1000 |
| | | 12" | F120H311DB906 | 300PSI | 36" | 600 |

| DESCRIPTION | MATERIAL |
|-----------------|---------------|
| 'A' PIPE SCH 40 | CARBON STEEL |
| 'B' CAPSULE | T-304 STN STL |
| 'C' BASE PLATE | CARBON STEEL |

| | | | | | |
|----------|--------------|---|----------|-------------------|-----|
| DRAWN | DG | KEFLEX PRODUCTS 1425 KAKE AVENUE WOODSTOCK, ILLINOIS 60098 | | | |
| DATE | 3 JAN 01 | | | | |
| CHECKED | | TITLE 311 DUAL CENTER BASE EXPANSION JOINT WELD ENDS [6" TRAVEL] | | | |
| APPROVED | DG | SIZE | FSCM NO. | DWG NO. | REV |
| QC | | A | 87738 | SUBMITTAL DRAWING | - |
| FILE | SUBDCBW7.DWG | SCALE NONE | | SHEET 1 OF 1 | |
| JOB | EJ/SUBMITTAL | | | | |

| | |
|-----------------|------|
| SUBMITTED BY: | DATE |
| CLIENT APPROVAL | DATE |